

2013 Annual Water Quality Report**(Consumer Confidence Report)**

This report is intended to provide you with important information about your drinking water and the efforts made to provide safe drinking water.

Attencion!

Este informe contiene información muy importante. Tradúscalo o pregúntele a alguien que lo entienda bien.

[Translated: This report contains very important information. Translate or ask someone who understands this very well.]

What is the source of my water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our water comes from the following source(s):

Source Name	Type
WELL # 9 - NEW S WELL	GROUND WATER
WELL # 5 - LAKEVIEW LN	GROUND WATER
WELL # 6 - ANITA DR	GROUND WATER
WELL # 7 - COPPER OAKS	GROUND WATER

Source Water Assessment:

The Department of Natural Resources conducted a source water assessment to determine the susceptibility of our water source to potential contaminants. This process involved the establishment of source water area delineations for each well or surface water intake and then a contaminant inventory was performed within those delineated areas to assess potential threats to each source. Assessment maps and summary information sheets are available on the internet at <http://maproom.missouri.edu/swipmaps/pwssid.htm>. To access the maps for your water system you will need the State-assigned identification code, which is printed at the top of this report. The Source Water Inventory Project maps and information sheets provide a foundation upon which a more comprehensive source water protection plan can be developed.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be present in source water include:

- A. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- B. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- C. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- D. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- E. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Natural Resources prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department of Health regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Is our water system meeting other rules that govern our operations?

The Missouri Department of Natural Resources regulates our water system and requires us to test our water on a regular basis to ensure its safety. Our system has been assigned the identification number MO5036006 for the purposes of tracking our test results. Last year, we tested for a variety of contaminants. The detectable results of these tests are on the following pages of this report. Any violations of state requirements or standards will be further explained later in this report.

How might I become actively involved?

If you would like to observe the decision-making process that affect drinking water quality or if you have any further questions about your drinking water report, please call us at [417-649-7237](tel:417-649-7237) to inquire about scheduled meetings or contact persons.

Do I need to take any special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Special Lead and Copper Notice:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CARL JUNCTION/BRIARBROOK SUBDIVISION is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://water.epa.gov/drink/info/lead/index.cfm>.

CARL JUNCTION/BRIARBROOK SUBDIVISION

MO5036006

2013 Annual Water Quality Report

(Consumer Confidence Report) Contaminants Report

Definitions:

Population: 3900. This is the equivalent residential population served including non-bill paying customers.
 MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
 MCL: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
 SMCL: Secondary Maximum Contaminant Level, or the secondary standards that are non-enforceable guidelines for contaminants and may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.
 AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow..
 TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.
 90th percentile: For lead and Copper testing. 10% of test results are above this level and 90% are below this level.
 Level Found: is the average of all test results for a particular contaminant.
 Range of Detections: Shows the lowest and highest levels found during a testing period, if only one sample was taken, then this number equals the Level Found.
 MRLDG: Maximum Residual Disinfectant Level Goal, or the level of a drinking water disinfectant below which there is no known or expected risk to health.
 MRDL: Maximum Residual Disinfectant Level, or the highest level of a disinfectant allowed in drinking water.
 RAA: Running Annual Average, or the average of sample analytical results for samples taken during the previous four calendar quarters.
 LRAA: Locational Running Annual Average, or the locational average of sample analytical results for samples taken during the previous four calendar quarters.

Abbreviations:

TTHM: Total Trihalomethanes (chloroform, bromodichloromethane, dibromochloromethane, and bromoform) as a group.
 HAA5: Haloacetic Acids (mono-, di- and tri-chloroacetic acid, and mono- and di-bromoacetic acid) as a group.
 ppb: parts per billion or micrograms per liter.
 ppm: parts per million or milligrams per liter.
 n/a: not applicable.
 NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.
 MFL: million fibers per liter, used to measure asbestos concentration.
 nd: not detectable at testing limits.

The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records with a sample year more than one year old are still considered representative.

Regulated Contaminants

Regulated Contaminants	Collection Date	Highest Value	Range (low – high)	Unit	MCL	MCLG	Typical Source
BARIUM	7/22/2013	0.133	0.123 - 0.133	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	7/22/2013	1.72	1.2 - 1.72	ppb	100	100	Discharge from steel and pulp mills
ETHYLBENZENE	7/22/2013	0.69	0 - 0.69	ppb	700	700	Discharge from petroleum refineries
FLUORIDE	7/22/2013	0.84	0.64 - 0.84	ppm	4	4	Natural deposits; Water additive which promotes strong teeth
NITRATE-NITRITE	10/9/2013	0.016	0 - 0.016	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
XYLENES, TOTAL	7/22/2013	0.00236	0 - 0.00236	ppm	10	10	Discharge from petroleum factories; Discharge from chemical factories

Lead and Copper	Date	90th Percentile	Range (low – high)	Unit	AL	Sites Over AL	Typical Source
COPPER	2011 - 2019	0.0194	0.00147 - 0.0682	ppm	1.3	0	Corrosion of household plumbing systems

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	2/29/2012	1.6	1.6	pCi/l	5		Erosion of natural deposits
GROSS ALPHA PARTICLE ACTIVITY	2/29/2012	7.2	7.2	pCi/l			Erosion of natural deposits
RADIUM-226	2/29/2012	1.6	1.6	pCi/l	5	0	

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2013				

Violations and Health Effects Information

During the 2013 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Type
No Violations Occurred in the Calendar Year of 2013		

CARL JUNCTION - NORTH

2013 Annual Water Quality Report

(Consumer Confidence Report)

MO5010138

This report is intended to provide you with important information about your drinking water and the efforts made to provide safe drinking water.

Atencion!

Este informe contiene información muy importante. Tradúscalo o pregúntele a alguien que lo entienda bien.

[Translated: This report contains very important information. Translate or ask someone who understands this very well.]

What is the source of my water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our water comes from the following source(s):

Source Name	Type
WELL # 8	GROUND WATER
WELL # 2	GROUND WATER
WELL # 3	GROUND WATER

Source Water Assessment:

The Department of Natural Resources conducted a source water assessment to determine the susceptibility of our water source to potential contaminants. This process involved the establishment of source water area delineations for each well or surface water intake and then a contaminant inventory was performed within those delineated areas to assess potential threats to each source. Assessment maps and summary information sheets are available on the internet at <http://maproom.missouri.edu/swipmaps/pwssid.htm>. To access the maps for your water system you will need the State-assigned identification code, which is printed at the top of this report. The Source Water Inventory Project maps and information sheets provide a foundation upon which a more comprehensive source water protection plan can be developed.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be present in source water include:

- A. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- B. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- C. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- D. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- E. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Natural Resources prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department of Health regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Is our water system meeting other rules that govern our operations?

The Missouri Department of Natural Resources regulates our water system and requires us to test our water on a regular basis to ensure its safety. Our system has been assigned the identification number MO5010138 for the purposes of tracking our test results. Last year, we tested for a variety of contaminants. The detectable results of these tests are on the following pages of this report. Any violations of state requirements or standards will be further explained later in this report.

How might I become actively involved?

If you would like to observe the decision-making process that affect drinking water quality or if you have any further questions about your drinking water report, please call us at [417-649-7237](tel:417-649-7237) to inquire about scheduled meetings or contact persons.

Do I need to take any special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Special Lead and Copper Notice:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CARL JUNCTION - NORTH is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://water.epa.gov/drink/info/lead/index.cfm>.

CARL JUNCTION - NORTH

2013 Annual Water Quality Report

(Consumer Confidence Report) Contaminants Report

MO5010138

Definitions:

Population: 3545. This is the equivalent residential population served including non-bill paying customers.
MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
SMCL: Secondary Maximum Contaminant Level, or the secondary standards that are non-enforceable guidelines for contaminants and may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.
AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow..
TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.
90th percentile: For lead and Copper testing. 10% of test results are above this level and 90% are below this level.
Level Found: is the average of all test results for a particular contaminant.
Range of Detections: Shows the lowest and highest levels found during a testing period, if only one sample was taken, then this number equals the Level Found.
MRLDG: Maximum Residual Disinfectant Level Goal, or the level of a drinking water disinfectant below which there is no known or expected risk to health.
MRDL: Maximum Residual Disinfectant Level, or the highest level of a disinfectant allowed in drinking water.
RAA: Running Annual Average, or the average of sample analytical results for samples taken during the previous four calendar quarters.
LRAA: Locational Running Annual Average, or the locational average of sample analytical results for samples taken during the previous four calendar quarters.

Abbreviations:

TTHM: Total Trihalomethanes (chloroform, bromodichloromethane, dibromochloromethane, and bromoform) as a group.
HAA5: Haloacetic Acids (mono-, di- and tri-chloroacetic acid, and mono- and di-bromoacetic acid) as a group.
ppb: parts per billion or micrograms per liter.
ppm: parts per million or milligrams per liter.
n/a: not applicable.
NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.
MFL: million fibers per liter, used to measure asbestos concentration.
nd: not detectable at testing limits.

The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records with a sample year more than one year old are still considered representative.

Regulated Contaminants

Regulated Contaminants	Collection Date	Highest Value	Range (low – high)	Unit	MCL	MCLG	Typical Source
BARIUM	1/16/2013	0.127	0.115 - 0.127	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	1/16/2013	1.24	1.12 - 1.24	ppb	100	100	Discharge from steel and pulp mills
ETHYLBENZENE	1/16/2013	1.7	0 - 1.7	ppb	700	700	Discharge from petroleum refineries
FLUORIDE	1/16/2013	0.75	0.62 - 0.75	ppm	4	4	Natural deposits; Water additive which promotes strong teeth
XYLENES, TOTAL	1/16/2013	0.00951	0 - 0.00951	ppm	10	10	Discharge from petroleum factories; Discharge from chemical factories

Lead and Copper	Date	90th Percentile	Range (low – high)	Unit	AL	Sites Over AL	Typical Source
COPPER	2011 - 2013	0.0345	0.00554 - 0.0358	ppm	1.3	0	Corrosion of household plumbing systems
LEAD	2011 - 2013	1.66	1.04 - 1.9	ppb	15	0	Corrosion of household plumbing systems

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	5/4/2012	1.5	1.5	pCi/l	5		Erosion of natural deposits
GROSS ALPHA PARTICLE ACTIVITY	5/4/2012	8.2	8.2	pCi/l			Erosion of natural deposits
RADIUM-226	5/4/2012	1.5	1.5	pCi/l	5	0	

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2013				

Violations and Health Effects Information

During the 2013 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Type
No Violations Occurred in the Calendar Year of 2013		

CARL JUNCTION - NORTH
2013 Annual Water Quality Report
(Consumer Confidence Report)

MO5010138

Optional Monitoring (not required by EPA)
Optional Contaminants

Monitoring is not required for optional contaminants.

Secondary Contaminants	Collection Date	Your Water System Highest Value	Range (low - high)	Unit	SMCL
ALKALINITY, CaCO3 STABILITY	1/16/2013	239	218 - 239	MG/L	
CALCIUM	1/16/2013	48.9	45 - 48.9	MG/L	
CHLORIDE	1/19/2010	7.92	6.08 - 7.92	MG/L	250
HARDNESS, CARBONATE	1/16/2013	210	196 - 210	MG/L	
IRON	1/16/2013	0.0466	0.0278 - 0.0466	MG/L	0.3
MAGNESIUM	1/16/2013	21.4	20.4 - 21.4	MG/L	
MANGANESE	1/16/2013	0.00226	0.0017 - 0.00226	MG/L	0.05
NICKEL	1/16/2013	0.00165	0.00138 - 0.00165	MG/L	0.1
O-XYLENE	1/16/2013	0.0025	0 - 0.0025	MG/L	10
PH	1/16/2013	7.73	7.51 - 7.73	PH	8.5
POTASSIUM	1/16/2013	3.09	2.67 - 3.09	MG/L	
SODIUM	1/16/2013	12	7.67 - 12	MG/L	
SULFATE	1/16/2013	25.9	20.6 - 25.9	MG/L	250
TDS	1/16/2013	247	224 - 247	MG/L	500
XYLENE, META AND PARA	1/16/2013	7.01	0 - 7.01	UG/L	
ZINC	1/16/2013	0.0542	0.0139 - 0.0542	MG/L	5

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.

CARL JUNCTION/BRIARBROOK SUBDIVISION

MO5036006

**2013 Annual Water Quality Report
(Consumer Confidence Report)****Optional Monitoring (not required by EPA)
Optional Contaminants***Monitoring is not required for optional contaminants.*

Secondary Contaminants	Collection Date	Your Water System Highest Value	Range (low - high)	Unit	SMCL
ALKALINITY, CaCO3 STABILITY	7/22/2013	183	166 - 183	MG/L	
CALCIUM	7/22/2013	33.2	28.6 - 33.2	MG/L	
CHLORIDE	7/22/2010	50.1	12.1 - 50.1	MG/L	250
HARDNESS, CARBONATE	7/22/2013	136	125 - 136	MG/L	
IRON	7/22/2013	0.144	0.0222 - 0.144	MG/L	0.3
MAGNESIUM	7/22/2013	14.4	12.9 - 14.4	MG/L	
MANGANESE	7/22/2013	0.0026	0.00178 - 0.0026	MG/L	0.05
O-XYLENE	7/22/2013	0.00074	0 - 0.00074	MG/L	10
PH	7/22/2013	7.94	7.82 - 7.94	PH	8.5
POTASSIUM	7/22/2013	3.48	1.79 - 3.48	MG/L	
SODIUM	7/22/2013	44.3	16.2 - 44.3	MG/L	
SULFATE	7/22/2013	17.5	13.5 - 17.5	MG/L	250
TDS	7/22/2013	256	180 - 256	MG/L	500
XYLENE, META AND PARA	7/22/2013	1.62	0 - 1.62	UG/L	
ZINC	7/22/2013	0.0392	0.00451 - 0.0392	MG/L	5

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.